

rev	change date	revision	name
d	08.24.12	Formatting and detail edits	KHL
e			
f			
g			
h			
i			
j			
k			
naming			

dwg by:	Date
BJW	3.12.2012
scale	
NONE	
material no	
ind	
Wiring Diagram	

WD 875 LE 01 120 D



Wiring Diagram for Local Control Station
P1 Series 120VAC Modulating Actuators

WD 875 LE 01 120 D.dwg

REV D


Description of Operation:
 Provides local/remote control of 120VAC P1 Series Proportional control actuators.
 Generates a 4 OR 20mA signal from the door switch to position the actuator when in Local Mode.
 A 4–20mA feedback signal is passed through the cabinet to the end user.

Aux switch cams are factory set at 5° and 85°. Moving these cams will affect the accuracy of the Open and Closed indicators.



Term Block Filename: Altech 875-LE01P120D

FacePlate Filename: 2 hole 5x7 Steel



Enclosure front & back hole patterns

Notes:
THIS IS AN 8X6X6 ENCLOSURE!

Specify Control:

- 4-20mA Control
- 2-10vdc Control

Use this solution for:
P1 Series

Use For:
OPT LCS LE 01 P/S/F 120 D/R

This document is the property of ProMation Engineering, Inc. Distribution of this document without the written consent of the owner is strictly forbidden. Failure to comply will incur a liability for damages.