

rev	change date	revision	name
D	08.24.12	Formatting and detail edits	KHL
C	09.03.2015	corrected terminal block layout	KHL
D			
E			
F			
G			
H			

noming	material no	ind	Wiring Diagram
dwg by: BJW	Date: 3.1.2012		
scale: NONE			

Promation

WD 875 LE 213 120 D



Wiring Diagram for Local Control Station
P2~13 Series 120VAC Modulating Actuators

WD 875 LE 213 120 D.dwg

REV B


Description of Operation:
 Provides local/remote control of 120VAC P2~13 Series Proportional control actuators.
 Generates a 4 OR 20mA signal from the door switch to position the actuator when in Local Mode.
 A 4~20mA feedback signal is passed through the cabinet to the end user.

Aux switch cams are factory set at 5° and 85°. Moving these cams will affect the accuracy of the Open and Closed indicators.



Terminal Block Layout (12X1)

Term Block Filename: Altech 875 LE213P120D
 FacePlate Filename: 2 hole 5x7 NO display Steel (No Stop)



Door Hole Pattern Back Hole Pattern
 Enclosure front & back hole patterns

Notes:
 THIS IS AN 8X6X6 ENCLOSURE!

Specify Control:

- 4-20mA Control
- 2-10vdc Control

Use this solution for:
 P2~13 Series

Use LE for:
 P1, PA & PL Series

Use For:
 OPT LCS LE P2~13 P/S/F 120 D/R

This document is the property of ProMation Engineering, Inc. Distribution of this document without the written consent of the owner is strictly forbidden. Failure to comply will incur a liability for damages.